

"NORTEKS AE" SIA

PHE Sondex - Izstrade un Datu saraksts

V10B35

Norteks AE

18.06.2018

001

Item: 2

PSA-Tips SL23-BR50-20-TL-LIQUID

Karsta puse Auksta puse

Paterins	(kg/s)	0.05	0.08
Ieejas temperatūra	(°C)	95.00	60.00
Izejas temperatūra	(°C)	65.00	80.00
Spiediena kritums	(kPa)	0.62	1.30
Jauda	(kW)	6	

Termodinamiskaas ipasibas

Water 40 EtGlycol

Blivums	(kg/mi)	971.96	1 047.20
Ipatnejais siltums	(kJ/kg*K)	4.19	3.63
Siltumvaditspeja	(W/m*K)	0.67	0.45
Videejaa viskozitaate	(mPa*s)	0.38	0.96
Sienas viskozitate	(mPa*s)	0.43	0.77
Pretapaugšanas faktori	(mI*K/kW)	0.05	0.04
Izmeru faktors	%	15.11	
Piepludes nodala		F1	F3
Izpludes nodala		F4	F2

Konstrukcija Ramis/Plaksnes

Plaksnu komplektesana (kanali)	1	x	9	+	0	x	0
Plaksnu komplektesana (kanali)	1	x	10	+	0	x	0
Plaksnu skaits	20						
Efektiva siltuma virsma	(mI)	0.43					
Pilns silt.vad.spej koef nosl(W/mI*K)	1	516.37		1	745.49		
Plaksnu materials	0.4 mm	AISI 316					
Blives materials / Max temp.	COPPER/BRAZED	/ 185					
Max. aprek. temperatūra	(°C)	140.00					
Max. Darba/izmeģinajuma spied(MPa)	1.60		2.08				
Max. Diferencialais spiediens(MPa)	1.60						
Piekrisana	None						
Skidruma apjoms	(dmi)	1					
Ramju garums	(mm)	53					
Neto svars	(kg)	3					
Strukturas tips	BR						
Savienojumi karsta puse :	0.75 inch. Thread BSP						
Savienojumi auksta puses:	0.75 inch. Thread BSP						

Sazinaaties ar Norteks AE par

"NORTEKS AE" SIA

Muitas iela 3E

Tel: +371 65425127

LV-5401 Daugavpils

Fax: +371 65425127